EQUIP: ENV. INSPECTION OF TANKS (METRO, RCRA, PSAPCA)

ADDENDUM: 0800

DATE JANUARY 1995

PAGE : 1 of 7

FREQ	SKILL	JOB DESCRIPTION			
DAILY	L6	INSP. TANKS FOR LEAKS/TANK COND. (PSAPCA)			
PROPERTY JOB NO.:	NO.: 65-0509 087352	95-001 (MET)	RO)		
ABF 140 ABF 141	3-369 3-369	WEST WEST	25,000 25,000	WASTE WATER WASTE WATER	
ABF 103 ABF 104 ABF 121	3-369 3-369 3-380	WEST WEST SOUTH	25,000 25,000 20,000	WASTE WATER WASTE WATER WASTE WATER	
ABF 122 ABF 112	3-380 3-369	SOUTH WEST	20,000 500	WASTE WATER HYDROGEN PEROXIDE	
	5/5/95	5/8/95	5/9/95	5/10/95	5/11/95
TANK	FRIDAY	MONDAY	TUESDAY	WEDNESDAY	THURSDAY
ABF 140	MC	me	MC	me	MC
ABF 141	MC	me	mc	MC	MC
ABF 103	MC	mc	me	me	mc
ABF 104	MC	mc	me	MC.	me
ABF 121	me	MC	me	me	mc
ABF 112	me	me	me	mc	me
ABF 122	me	me	me	mc	me

- 1. INSPECT EACH TANK LISTED ABOVE, AND ASSOCIATED PIPING AND PUMPS, DAILY. INSPECT FOR LEAKAGE OR DAMAGE. CHECK INTERSTITIAL SPACE MONITOR, IF TANK IS SO EQUIPPED, FOR LEAK INDICATION.
- 2. HAND SIGN INSPECTION SHEET
- 3. NOTE ANY REPAIRS NEEDED AND DATE REPORTED.
- 4. REQUEST A WORK CLASS 22 (PLANNED JOB) FOR ANY REPAIRS REQUIRED.
- 5. FILE THIS INSPECTION RECORD AT THE ENVIRONMENTAL OPERATIONS OFFICE.

>>>>>>>> End of Page 1

BCA FACILITIES SERVICES NBF

ADDENDUM INSTRUCTIONS

EQUIP: ENV. INSPECTION OF TANKS (METRO, RCRA, PSAPCA)

DATE JANUARY 1995

ADDENDUM: 0800 PAGE: 2 of 7

PROPERTY NO.: 65-050995-001 (METRO)

JOB NO.: 087352

6. ENSURE STRIPPING TOWER IS CLEAR FROM OBSTRUCTIONS AND OPERATES . PROPERLY.

RETURN COMPLETED ADDENDUM TO YOUR SUPERVISOR.

COMPLETED BY:

DATE

TIME:

SUPERVISOR:

DATE

KEEP THIS AND ALL ENVIRONMENTAL PAPERWORK TOGETHER FOR FIVE (5) YEARS.

End of Page 2